

Contact: Melissa / April

Hollister City Fire Department

110 Fifth Street ♦ Hollister, California 95023-3985 ♦ (831) 636-4325 ♦ fax (831) 636-4329


FIRE SAFETY INSPECTION REPORT

Business Address: 1131 San Felipe Rd. Suite: _____ Inspection Date: 2-12-21

Business Name: SBC Behavioral Health Business Phone: 831-636-4020 Fax: _____

Owner/Property Management: Community Services Development Corp Phone: _____ Emergency Phone: _____

Address: _____ City: _____ State: _____ Zip: _____

No.	✓✖	Violations	No.	Location / Remarks	Cleared
ACCESS					
1		Maintain fire lanes free obstructions.	7	Main office Lobby	11
2		Provide fire lane identification.			
3		Provide address numbers/ building I.D. visible from street.			
4		Provide approved knox box, locks, switch and caps required for Fire Dept. access.			
EXITING					
5		Remove obstruction at exits, doors, aisles, corridors, stairways, etc.		Provide visual & Audible Alarm for the building	
6		Exits door to open without a key or any special knowledge/effort.			
7	✓	Provide Sign over main exit door, "This Door to remain unlocked... business hours".			
8		Repair non-operable exit door hardware.			
9		Remove obstructions from door required to be closed.			
10		Remove locks or latches from doors with panic hardware.			11
11		Place an Exit sign above exit door.		NO Smoke Detectors	
12		Repair non- working exit signs and exit illumination.			
13		Post occupant load sign in designated room.			
ELECTRICAL					
14		Discontinue use of extension cords.			11
15		Install permanent wiring for fixed and stationary appliance.			
16		Provide cover plate for all junction boxes.			
17		Remove exposed wiring or protect in approved conduit.			
18		Provide a 30" clear space to and in front of electrical box panels.			
19		Discontinue using cube taps.			11
20		Provide covers for unused openings in electrical panel boxes.			
FIRE EXTINGUISHER					
21		Have fire extinguisher serviced and tagged.			
22		Provide and mount a fire extinguisher as indicated. (2-A- 10-BC)			
23		Mount existing fire extinguisher in an approved location.			11
24		Post a sign indicating the location of fire extinguisher.			
25		Provide clear access to the fire extinguisher.			
FIRE PROTECTION EQUIPMENT					
26		Remove obstructions (3ft .min. clearance) for access and use of fire equipment and appliances. (FDC, Standpipe, Risers, Alarm panels, Hydrant	1st		
27		Provide 5 year certification test for sprinkler and standpipe system.	2nd		
28		Secure all system control valve in the open position.			
29		Replace missing caps on fire department connection with Knox FDC caps.	Refer FPB		
30		Provide sprinkler coverage in unprotected areas.			
31		Provide spare sprinkler heads and / or wrench at riser.	3rd		
32		Replace damage, corroded or painted sprinkler heads.	Hearing		
33		Hood and duct extinguishing system to be serviced and tagged.	District Attorney		
34		Remove grease from hood, ducts and filters. (And keep them clean).			
35		Fire alarm system to be tested by qualified persons.	Final clearance		
36		Have fire door inspected and tested.	Occupancy Class:	<input type="checkbox"/> Change of Occupancy	<input type="checkbox"/> Check Occupancy Drawing for accuracy
FLAMMABLE AND COMBUSTIBLE LIQUIDS					
37		Provide Flammable Liquid storage cabinet or reduce storage	You are notified to correct all violation immediately or Show cause why you should not be required to do so. A re-inspection will be conducted after _____ Days from The date of this notice. Willful failure to comply with this notice is a misdemeanor. Violation which are not Correct immediately and /or remain after the re-inspection May be processed as a criminal offense. Thank you for Your assistance and cooperation in minimizing the fire And life loss in your community.		
38		Provide inside storage room or reduce storage.	BY ORDER OF THE FIRE MARSHAL		
39		Discontinue dispensing of flammable by gravity.	Pre- Citation Letter Date:		
40		Replace lids on all storage not in immediate use	Signature of recipient:		
41		Provide approved bonding / grounding when dispensing flammable liquids.			
STORAGE AND HOUSEKEEPING					
42		Reduce storage to at least 42" below ceiling (no Sprinklers) .	Inspecting officer: <u>G. Belencourt</u>		
43		Reduce storage to at least 18" below sprinkler heads.	Shift: _____ Company: _____ Page # _____ Of _____		
44		Arrange storage in orderly manner to provide access/ egress.	<u>Prevent</u>		
45		Remove combustibles storage from boiler, mechanical, electrical rooms.	For Fire Prevention Bureau Use:		
46		Provide 30" clearance of combustible from heating equipment.			
47		Remove waste and rubbish materials from the premises.			
48		Relocate dumpster to an approved location.			
49		Repair holes in required fire resistive construction and / or interior wall and ceiling finishes.			
50		Remove weeds, rubbish, refuse, and flammable materials.			
51		Provide approved metal container for oily rag storage.			
GASES					
52		Secure compressed gas cylinder.			
OTHER					
53		Other Violation and comments.			
54		No Violation noted at this time. Life safety exists.			

WHITE - FPB

YELLOW - Engine Company

PINK - Occupant